

	Technical Standards and Safety Authority INSPECTION PROCEDURE	January 25, 2008
	Procedure for Testing Emergency Lighting	Rev. 0

The reference to this requirement is found in the A17.2 Guide for Inspection of Elevators, Escalators, and Moving Walks, Item 1.5.1 (b).

- When auxiliary lighting is supplied, check its operation by disconnecting the normal lighting supply.
- Where the auxiliary lighting is supplied by batteries, check that such batteries are in good condition and properly maintained, and that any recharging equipment is operable.
- Check that the auxiliary power supply is located on each elevator.