



Fuels Safety Program	Ref. No.: FS- 174- 10	Rev. No.:
PROPANE CODE ADOPTION DOCUMENT - AMENDMENT	Date: July 14, 2010	Date:

**IN THE MATTER OF:
THE TECHNICAL STANDARDS AND SAFETY ACT, 2000,
S.O. 2000, c. 16**

- and -

**ONTARIO REGULATION 223/01 (Codes and Standards Adopted by Reference)
made under the Act**

- and -

**ONTARIO REGULATION 211/01 (Propane Storage and Handling)
made under the Act**

Subject: Supply of Propane to Direct Fired Vapourizers
Sent to: Propane Advisory Council, Propane Risk Reduction Groups, Interprovincial Gas
Advisory Council (IGAC), Posted on TSSA's Web-Site

The Director of Ontario Regulation 211/01 (Propane Storage and Handling), pursuant to section 9 of Ontario Regulation 223/01 (Codes and Standards Adopted by Reference), hereby provides notice that the Propane Code Adoption Document published by the Technical Standards & Safety Authority and dated June 1, 2001, as amended, is further amended as follows:

1. Section 9.3 of CSA B149.2-05 (Propane Storage and Handling Code) is amended by adding the following clause:

9.3.6 For propane tanks having a liquid withdraw line to a direct-fired vapourizer, an emergency shutdown system shall be installed in any tank system supplying propane to a direct-fired vapourizer. The electric, mechanical or pneumatic shutoff system shall be able to be activated by pushing a panic button, or by pulling a chain or cable. The shutoff shall be located at least 25 ft away from the vaporizer, and be able to terminate the supply of propane to the direct fired vapourizer by closing the valves at the liquid line at the tank.

2. This amendment is effective immediately for newly installed tanks and is effective no later than December 31, 2012 for existing propane tanks.

Dated at Toronto this 14th.day of July, 2010


John R. Marshall
Statutory Director

O.Reg. 211/01 (Propane Storage and Handling), made under the *Technical Standards & Safety Act*