



Fuels Safety Division	Ref. No.: FS-069 / 05	Rev. No.:
DIRECTOR'S ORDER	Date: December 15, 2005	Date:

**IN THE MATTER OF:
THE TECHNICAL STANDARDS AND SAFETY ACT 2000,
S.O. 2000, c. 16**

- and -

**ONTARIO REGULATION 223/01 made under the
Technical Standards & Safety Act, 2000
(Codes and Standards Adopted by Reference)**

- and -

**ONTARIO REGULATION 217/01 made under the
Technical Standards and Safety Act, 2000
(The Liquid Fuels Regulation)**

Subject: Deletion of Requirement to Ease up on the Nozzle Trigger
Sent to: Liquid Fuels Councils and RRG's and Posted on Website

The Director of Ontario Regulation 217/01 (Liquid Fuels) pursuant to section 7 of Ontario Regulation 223/01 (Codes and Standards Adopted by Reference) hereby provides notice of the following:

The Liquid Fuels Code Adoption Document published by the Technical Standards & Safety Authority and dated June 1, 2001, and amended August 1, 2005 by Director's Order is amended as follows:

1. Clause 5.1.6 is revoked.
2. The signs that were required by clause 5.1.6 shall be removed.
3. The said amendments are effective immediately.

Explanation

Clause 5.1.6 provides that:

At each self-serve dispenser there shall be installed a legible sign visible to all persons using the dispenser with minimum dimensions of 18.5 cm by 8.25 cm bearing the words:

“WARNING: TO AVOID SPILLAGE EASE UP ON THE NOZZLE TRIGGER WHEN FILLING THE TOP PORTION OF THE TANK”

The above requirement may reduce the flow rate below the low reliable shut-off where there is not enough fuel flowing through the venturi to create a vacuum to shut off the nozzle. As a result the said clause is deleted.

Dated at Toronto this 15th day of December 2005.

Roland Hadaller
Statutory Director
O.Reg. 217/01 (Liquid Fuels)
made under the *Technical Standards & Safety Act*