



## FUELS SAFETY DIVISION

Revised January 1998  
NG 98/3 PR 98/2

### **ADVISORY**

#### **ENERGY ACT NATURAL GAS UTILIZATION CODE ONTARIO PROPANE CODE**

#### **CONVERSION OF NATURAL GAS FIRED APPLIANCES TO PROPANE AND PROPANE FIRED APPLIANCES TO NATURAL GAS**

Clause 3.5.3 of the Ontario Gas Utilization Code, O.Reg. 546/96 and Ontario Propane Storage Handling and Utilization Code, O.Reg. 514/96 states that:

***“3.5.3 When an **appliance** is converted from the “Fuel” specified on the rating plate, the conversion shall be in accordance with the manufacturer’s **certified** instructions. If there are no manufacturer’s instructions for conversion of the **appliance**, the converted **appliance** shall be **approved**.”***

It is the responsibility of the fitter making the conversion to convert the appliance in accordance with the manufacturer’s certified conversion instructions.

When converted from one gas to the other, appliances that are not certified for conversion shall be treated as new appliances requiring field approval.

To arrange for such approval, please contact Mr. Z. Fraczkowski at Technical Standards and Safety Authority, telephone (416) 325-1681.