



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario MBX 2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
 Propane Storage and Handling Regulation

- This Level 1 RSMP applies to:
- a facility with a total propane storage capacity of 5,000 USWG or less; or
 - a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection.
 Making a false statement may result in a fine or prosecution
 under the *Technical Standards and Safety Act*

Licence Number 0076467786-C

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.



SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

Company Name Costco Wholesale Ltd. Ontario Corporation No., if applicable _____

A Operator Name (if different from above)
Darren Pudrycki (Warehouse Manager of the Nepean store phone: 613-727-4768)

Telephone No. 1-800-463-3783 Fax No. N/A E-mail service@costco.ca

B Street No. 415 Street Name / 911 Number / Address, if applicable West Hunt Club Road

Town / City or Township / County Ottawa Province Ontario Postal Code K2E 1C5

Mailing address if different from above.

C Street No. _____ Street Name / 911 Number / Address, if applicable _____

Town / City or Township / County _____ Province _____ Postal Code _____

Information on Container Refill Centre or Filling Plant

Location of facility.

D Street No. 1849 Street Name / 911 Number / Address, if applicable Merivale Road Nearest Major Intersection Merivale Road & Hunt Club Road

Town / City or Township / County Nepean Province Ontario Postal Code K2G 1E3

Name of Licence Holder Larry Pifer (Warehouse Manager @ Nepean store)

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT). Robert Moyer ROT type PTI 100-08

Municipality (or municipalities if the facility or its hazard distance touches multiple borders)
City of Ottawa

Hours of operation.

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name	Signature	Date (dd-mm-yyyy)
Name of Licence Holder <u>Darren Pudrycki (Warehouse Manager @ Nepean store)</u>		<u>16-10-2013</u>
Name of Senior Management person as defined in the Regulation holding the Record of Training <u>Robert Moyer</u>		<u>16-10-2013</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)


Indicate the year the facility was established. 1996 Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. November 2013 - TMS system installed

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	<u>250 psig</u>	<u>unknown at this time</u>
Tank 2:	_____	_____
Tank 3:	_____	_____

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 USWG Portable: 279 USWG Mobile: 0 USWG



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Ken Mole</u>	Official Title <u>Project Manager</u>	
Signature 	Telephone No. <u>416-229-2636</u>	Date (dd-mm-yyyy) <u>16-10-2013</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)
Activity Information

Name of Propane Supplier(s) Superior Propane - Ontario Regional Operations Centre			For Office Use - Party No.	
Street No. 251	Street Name / 911 Number / Address, if applicable Woodlawn Road West, Unit 217			
Town / City or Township / Country Guelph			Province Ontario	Postal Code N1H 8J1
Telephone No. 1-877-873-7467	Fax No. 519-836-7766	Contact Name Bruce Graham, Ontario Operations Manager		
E-mail grahamb@superiorpropane.com				

Name of Propane Transporter. If same as above, please check box. <input type="checkbox"/>			For Office Use - Party No.	
Superior Propane - Ottawa Propane Bulk Plant				
Street No. 63	Street Name / 911 Number / Address, if applicable Roydon Place			
Town / City or Township / Country Ottawa			Province Ontario	Postal Code K2E 1A3
Telephone No. 613-314-8003	Fax No. N.A	Contact Name Heather Ross, Market Manager		
E-mail rosshe@superiorpropane.com				

Off-site Cylinder and/or Mobile Storage None		Capacity stored off-site, in USWG	For Office Use - Party No.	
Street No.	Street Name / 911 Number / Address, if applicable			
Town / City or Township / Country			Province	Postal Code
Telephone No.	Fax No.	Contact Name		

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager	
Signature 	Telephone No. 416-229-2636	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

None

Description of fire and emergency equipment indicated on facility site map.

1. Fires extinguisher locations: a) 1 on the inside pillar of the canopy by the propane filling station, b) 2 in the tire centre c) and 1 at tire sales.
2. Fire Department Connection - located inside the tire centre, immediate notification to Fire Services.
3. Emergency stop push button located outside of the tire centre. This will shut down the pump and close a solenoid valve upstream of hoses.
4. Power supply breaker located inside the building will cut all power to the system.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

1. E-Stop on outside wall (at tire centre) - cuts all power except 24 DC, shuts down the pump, and closes a solenoid valve (upstream of hoses) to stop flow.
2. Power supply breaker inside the building - cuts all power to the propane system, shuts down the pump, and closes solenoid valve.
3. Fusible link on ISC valve - isolation valve between the tank and the downstream propane dispensing equipment.
4. ISC valve interlock bar (interlocked with cabinet door) - ISC valve closes when door is closed.
5. Leak Detection System at dispenser will trigger system shutdown @ 60% LFL and triggers audible alarm.

Maintenance and testing schedule for fire protection controls and devices.

1. Fire extinguishers will be maintained by Costco as per Ontario Fire Regulations and replaced as per manufacturer's recommendations.
2. The gas detection/auto shutdown/audible alarm system will be maintained and tested every 6 months by Total Meter Service.
3. Other equipment - i.e., pumps, valves, etc. will be maintained/tested by Superior Propane according to the requirements in the Superior Propane Maintenance Standard. According to this Standard - ISC valves will be tested every 6 months; pumps will be maintained every 3 months. Fusible links inspected twice annually. Records kept for 5 yrs.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager	
Signature 	Telephone No. 416-229-2636	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact

Name <u>Todd Wagner</u>	For Office Use - Party No.
Official Title <u>Tire Centre Manager</u>	
Telephone No. <u>613-727-4786</u>	Fax No. <u>613-727-0237</u>
E-mail <u>w540tsm@costco.com</u>	
Role and responsibilities in emergency <u>Coordinate site response</u>	

5. Facility 24-Hour Contact Person

Name <u>Darren Pudrycki</u>	For Office Use - Party No.
Official Title <u>Warehouse Manager</u>	
Cell No. <u>613-286-4030</u>	Fax No. <u>613-727-0237</u>
E-mail <u>w540mgr@costco.com</u>	
Role and responsibilities in emergency <u>Coordinate site response</u>	

2. Facility Contact Personnel - Alternate Contact

Name <u>Daryl Hunt</u>	For Office Use - Party No.
Official Title <u>Assistant Warehouse Manager</u>	
Telephone No. <u>613-727-4786</u>	Fax No. <u>613-727-0237</u>
E-mail <u>w540mgr4@costco.com</u>	
Role and responsibilities in emergency <u>Coordinate site response if agent unavailable.</u>	

6. Name of Facility Manager

Name <u>Darren Pudrycki</u>	For Office Use - Party No.
Official Title <u>Warehouse Manager</u>	
Telephone No. <u>613-727-4786</u>	Fax No. <u>613-727-0237</u>
E-mail <u>w540mgr@costco.com</u>	
Role and responsibilities in emergency <u>Coordinate site response</u>	

3. Local Fire Services - Key Contact

Name <u>John DeHooge</u>	For Office Use - Party No.
Official Title <u>Fire Chief - City of Ottawa</u>	E-mail <u>rocco.iamello@ottawa.ca</u>
Telephone No. <u>john.dehooge@ottawa.ca</u>	Fax No. <u>613-580-2864</u>
Role and responsibilities in emergency <u>Coordinate/advise on Fire Service response. Liaise with police.</u>	
Fire Services Address <u>1445 Carling Ave., 2nd Floor, Ottawa, ON K1Z 7L9</u>	

7. Propane Supplier Key Contact Person

Name <u>Superior Propane</u>	For Office Use - Party No.
Official Title <u>HOTLINE</u>	E-mail <u>N/A</u>
Telephone No. <u>1-877-873-7467</u>	Fax No. <u>N/A</u>
Role and responsibilities in emergency <u>Identify and dispatch Superior Propane and/or LPERGC emergency response personnel as required.</u>	
Propane Supplier Address <u>251 Woodlawn Rd., Guelph, ON N1H 8J1</u>	

4. Local Fire Services - Alternate Contact

Name <u>Rocco Iamello</u>	For Office Use - Party No.
Official Title <u>Division Chief - Fire Prevention</u>	E-mail <u>rocco.iamello@ottawa.ca</u>
Telephone No. <u>613-580-2424</u>	Fax No. <u>613-580-2864</u>
Role and responsibilities in emergency <u>Alternate - Coordinate/advise on Fire Service Response. Liaise with police.</u>	
Fire Services Address <u>101 Centre Point Dr., 3rd Floor, Ottawa, ON K2G 5K7</u>	

8. Municipal Contact

Name <u>Mitchell LeSage</u>	For Office Use - Party No.
Official Title <u>Development Information Officer - City of Ottawa</u>	
Telephone No. <u>613-580-2424 x13902</u>	Fax No. <u>613-580-2687</u>
E-mail <u>Mitchell.LeSage@ottawa.ca</u>	
Municipality Name and Address <u>110 Laurier Avenue West, Ottawa, ON K1P 1J1</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Ken Mole</u>	Official Title <u>Project Manager</u>
Signature 	Telephone No. <u>416-229-2636</u>
	Date (dd-mm-yyyy) <u>16-10-2013</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation


SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

1. Leak Detection System at dispenser will trigger system shutdown @ 60% LFL (cuts all power except 24 VDC) and triggers an audible alarm.
2. E-Stop on outer wall of building (at tire centre) will cut all power (except 24 DC), shut down the pump, and close a solenoid valve (upstream of hoses) to stop flow.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager	
Signature 	Telephone No. 416-229-2636	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) 01-01-2013	Print Name of Training Provider: Costco Standard Safety Training (in-house)
	Print Name of Instructor: Warehouse Manager trained Department Managers
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy) 01-01-2013	Print Name of Training Provider: Costco Standard Safety Training (in-house)
	Print Name of Instructor: Department Managers trained their staff - upon hire and annual refresher training
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy) 16-05-2013	Print Name of Training Provider: Superior Propane	Please see list at end of this form
	Print Name of Instructor: Moe Bourcier	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Training Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager
Signature 	Telephone No. 416-229-2636
	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) TBA 01-01-2014	Print Name of Training Provider: Costco Standard Safety Training (in-house) - Department Managers
	Print Name of Instructor: Warehouse Manager to train Department Managers
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy) TBA 01-01-2014	Print Name of Training Provider: Costco Standard Safety Training (in-house)
	Print Name of Instructor: Department Managers to train their staff
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy) To Be Arranged as Required	Print Name of Training Provider: Superior Propane or Other	Please Note - a ROT is valid for 3 years
	Print Name of Instructor: TBA	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	
Target Date (dd-mm-yyyy)	Print Name of Training Provider:	
	Print Name of Instructor:	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager
Signature 	Telephone No. 416-229-2636 Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).
The operator or alternate will contact emergency services by calling 911 and will provide warnings outlined in the attached "Propane Emergency Response Procedures" card (to be posted on site and part of the employee training). If it is safe to do so this could involved advising neighbors to evacuate. The owner/operator may also contact Superior Propane via the emergency number identified in the ERP.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).
The owner/operator or alternate should first follow the actions in the ERP provided herein. Staged evacuation, if the release of propane cannot be stopped by cutting electrical power may be required. The initial muster location will be on the grass boulevard in front of the 'Putting Edge' building, in a safe area and away from a dispersing propane cloud. Subsequent evacuation instructions potentially up to the Hazard Distance to be provided by municipal emergency responders. Residences and businesses beyond the site boundary to be notified by municipal emergency responders.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).
When the system is operational, a ROT person will be on duty and be in the propane tank area. They key contact or alternate will be implementing ER actions including notifying emergency responders. Calling 911 will occur immediately after any attempts to shut down the system.
When the system is not in operation, the ISC valve (main isolation valve) is closed and the propane system is unattended but shutdown.
Any accidents involving the propane tank during such times will require the intervention of random, nearby individuals or staff.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.
The propane tank system is located in a wide open store parking lot area that is easily accessible from Merivale Road and Roydon Place.
The fire access routes are identified in the attached site plan.

Describe how the licence holder will ensure continual flow of updated information to authorities.
The critical information required from the license holder is information on how to shut down the system and the fill level in the tank (if known).
Fill level is relevant from a time to BLEVE perspective (a nearby empty tank will BLEVE sooner than a full tank if there is fire impingement on the tank).
This information will be provided to the authorities by Larry Pifer either verbally if on-site or by phone if after hours.

How long will it take the facility liaison person to respond to the site.
It would take the 24-hour contact, Larry Pifer, approximately 40 minutes to arrive on site after receiving an emergency call.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager	
Signature 	Telephone No. 416-229-2636	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	<u>175 m</u>	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	<u>N/A</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager	
Signature 	Telephone No. 416-229-2636	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services	Yes	No
Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?	<input type="checkbox"/>	<input type="checkbox"/>
If not, please explain (e.g., no fire services).		
<hr/> <hr/>		
Fire services comments, if any:		
<hr/> <hr/>		
To be completed by the Licence Holder		
In response to the above comments, the following action(s) is required:		
<hr/> <hr/>		
The licence holder will respond to the Local Fire Services comments by: _____		
(dd-mm-yyyy)		

LOCAL FIRE SERVICES		
The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.		
Print name	Signature	Date (dd-mm-yyyy)
Local Fire Services Name		

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager	
Signature 	Telephone No. 416-229-2636	Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) 23-07-2012	Capacity of single largest propane storage vessel (USWG) 2000 USWG
Tank setback coordinates. Indicate placement on the map.	
Front: 160 m South	Right side property line: 75 m East
Rear: 260 m North	Left side property line: 130 m West
GPS coordinates of single largest vessel: Lat.44.3339 Long.-79.6812	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ken Mole	Official Title Project Manager
Signature 	Telephone No. 416-229-2636 Date (dd-mm-yyyy) 16-10-2013



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)





Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: <u>None within the Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. Name: _____ Address: _____ City: _____	X				<u>0</u> m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>Various retail and restaurants - PetSmart, Party Packagers, Canada Computers, Goodlife Fitness,</u> Address: <u>Kelsey's, Century 21, Superior Propane, Sleep Canada, Rona, etc.</u> City: _____ Province _____ Postal Code _____			X		<u>75</u> m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: <u>None within the Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: <u>None within the Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: <u>None within the Hazard Distance</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Ken Mole</u>	Official Title <u>Project Manager</u>
Signature 	Telephone No. <u>416-229-2636</u> Date (dd-mm-yyyy) <u>16-10-2013</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

WORKSHEET

Portable Storage Additional Information Worksheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	48	278.4
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			279 USWG


Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
0	0	0
Total Tank Capacity		0 USWG

Total Cylinder Capacity	279 USWG
Total Tank Capacity	0 USWG
Total Portable Capacity (Total Cylinder Capacity + Total Tank Capacity)	279 USWG




Scale (m):



2000 USWG
Propane Tank

Site Boundary

Hazard Distance
= 246 m



©2011 Google – Imagery
©2011 Digital Globe, Cnes/Spot Image, First Base Solutions,
Map data ©2011 Google, Tele Atlas


Setback Distances to Site Boundary (approx)
North : 260 m West: 130 m
South: 160 m East: 75 m

Capacity of Propane Storage Tank:
Capacity of Propane Storage Tank = 2000 USWG
GPS Co-ordinates of Propane Storage Tank:
GPS Co-ordinates = 45.3373-75.7228

Circular Distance to 1 psi overpressure:
Denoted by circle centred on tank radial distance= 246m

Map of Surrounding Area
Costco
1849 Merivale Road, Nepean, ON, K2G 1E3
CON A R F S PT LOT 29 RP 4R-11472
PART 6
K. Almey - July 23 2012

Municipality (ies) within the 1 psi overpressure circle:
City of Ottawa
Municipal Contact:
Francoise Jessop
Program Manager for Zoning
City of Ottawa
110 Laurier Ave West
4th Floor West Building
Ottawa, ON, K1P 1J1
Tel: 613-580-2424 ext. 13862
Email: francoise.jessop@ottawa.ca



Class I Division I

Class I Division II

Inside Building

ITEM	QTY	DESCRIPTION	REMARKS
		<p>Class I Division I</p> <p>Class I Division II</p> <p>Inside Building</p>	

DRAWING ISSUE RECORD		REVISIONS	
ISSUE	DATE	BY	DESCRIPTION
1	7/25/2011		DESIGNED
2			CHECKED
3			PROCESS CHKD
			MECHANICAL CHRD
			ELECTRICAL CHRD
			CHEMICAL CHRD
			CLIENT APPROVED
			CLIENT APPROVED

FILE NAME	DESCRIPTION
C:\DOCUMENTS AND SETTINGS\CATANGUIDE\KTOPICSTCO INSTALLATION DRAWINGS REV 0110725 IC.VSD	
REF DRAWINGS / DOCUMENTS	
REF DRAWINGS / DOCUMENTS	
REF DRAWINGS / DOCUMENTS	
REF DRAWINGS / DOCUMENTS	

TOTAL METER SERVICES INC.	
158 CREDITSTONE ROAD	
VALUETOON, VT 05475	
PHONE 866-669-7071 FAX 866-669-7076	

TITLE	DESCRIPTION
COSTCO PROJECT	
	Piping and Instrumentation Diagram (P&ID)
DWG	

DATE	BY	APPROVED



T-0637-E6019