



Technical Standards and Safety Authority
 www.tssa.org
 14th Floor - Centre Tower
 3300 Bloor Street West
 Toronto Ontario M8X 2X4
 Fax: 416.231.4903
 Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
 Propane Storage and Handling Regulation

- This Level 1 RSMP applies to:
- a facility with a total propane storage capacity of 5,000 USWG or less; or
 - a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.


Failure to fully complete this form may result in rejection.
 Making a false statement may result in a fine or prosecution under the *Technical Standards and Safety Act*

Licence Number 000076641721

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.



SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

A Company Name Blueberry Hill Motel & Campground Ltd Ontario Corporation No., if applicable 1584848

Operator Name (if different from above) E. MURDOCK - D. Houle

Telephone No. 705-649-5631 Fax No. 705-649-4100 E-mail Address dianehoule@sympatico.ca

B Street No. 2528 D Street Name, Lot / Concession No. Hwy 17 North

Town / City or Township / County Goulais River Province ON Postal Code P0S 1E0

Mailing address if different from above.

C Street No. 2528 D Street Name, Lot / Concession No. RR2

Town / City or Township / County Goulais River Province ON Postal Code P0S 1E0

Information on Container Refill Centre or Filling Plant

Location of facility.

D Street No. 2528 D Street Name, Lot / Concession No. Hwy 17 North Nearest major intersection PINESHORE RD

Town / City or Township / County Goulais River Province ON Postal Code P0S 1E0

Name of Licence Holder ERNEST L. MURDOCK

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT). ERNEST L. MURDOCK ROT type PP0-3

Municipality (or municipalities if the facility or its hazard distance touches multiple borders) Goulais River

Hours of operation.

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of Licence Holder Ernest L. Murdock Signature [Signature] Date (dd-mm-yyyy) 10-10-11

Name of Senior Management person as defined in the Regulation holding the Record of Training E. L. MURDOCK

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
2528 D R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)


Indicate the year the facility was established. 1980 Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment. NEW DISPENSER & TANK 2004

Identify the psig rating and serial number for each fixed propane storage tank on site.

	PSIG	Serial Number
Tank 1:	<u>250 at 125F</u>	<u>39776</u>
Tank 2:	<u>0</u>	<u>0</u>
Tank 3:	<u>0</u>	<u>0</u>

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 1000 USWG Portable: N/A Mobile: N/A



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Ernest L. Murdock</u>	Official Title <u>MANAGER OWNER</u>	Date (dd-mm-yyyy) <u>10-10-11</u>
Signature <u>[Signature]</u>	Telephone No. <u>705-649-5631</u>	

10/10/11
 10:10:11
 10:10:11
 10:10:11
 10:10:11



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)
Activity Information

Name of Propane Supplier(s) <i>McDougal Energy Inc</i>			
Street No. <i>52</i>	Street Name Lot / Concession No. <i>Black Rd</i>		
Town / City or Township / Country <i>Sault Ste Marie</i>		Province <i>ON</i>	Postal Code <i>P6B 0A4</i>
Telephone No. <i>705-949-6202</i>	Fax No. <i>705-949-2539</i>	Contact Name <i>Steve Hilderley</i>	
E-mail <i>stehilderley@mcDougalcorp.com</i>			

Name of Propane Transporter. If same as above, please check box. <input checked="" type="checkbox"/>			
Street No.	Street Name Lot / Concession No.		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage <i>N/A</i>	Capacity stored off-site, in USWG	For Office Use - Party No.
Street No.	Street Name Lot / Concession No.	
Town / City or Township / Country		Postal Code
Telephone No.	Fax No.	Contact Name

Note: Customer storage is not considered off-site storage.

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
2528 D.R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest H. Murdock</i>	Official Title <i>OWNER</i>
Signature <i>[Signature]</i>	Telephone No. <i>705-649-7631</i>
	Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

NONE

Description of fire and emergency equipment indicated on facility site map.

FIRE EXTINGUISHERS AT DISPENSER, IN THE BLDG
CLOSE BY & AT THE OFFICE

FIRE/HEAT DETECTORS IN MOTEL & MAIN BLDG.


List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

SHUT OFF DEVICE ON THE DISPENSER - SHUT OFF VALVE
ON BLDG CLOSE BY ALSO (15m.) SIGNS WITH INSTRUCTION
BY DISPENSER & BY VALVE ON BLDG.

DISPENSER IS STAND ALONE - 15m. FROM BLDG USED

Maintenance and testing schedule for fire protection controls and devices. SEASONALLY.

ANNUAL INSPECTION & TESTING DONE BY MCDUGALL.



BLUESBERRY HILL MOTEL &
CAMPBELL LTD
5258 DERRIS HWY 17N
Goulds River, ON P0B 1E0

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest L. McDugall</i>	Official Title OWNER
Signature <i>E. McDugall</i>	Telephone No. 705-649-5631
	Date (dd-mm-yyyy) 10-10-11



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name <i>ERNEST MURDOCK</i>	For Office Use - Party No.	Name <i>ERNEST MURDOCK</i>	For Office Use - Party No.
Official Title <i>OWNER</i>		Official Title <i>OWNER</i>	
Telephone No. <i>705-649-5631</i>	Fax No. <i>705-649-4000</i>	Cell No. <i>705-649-4819</i>	Fax No. <i>705-649-4100</i>
E-mail <i>dianehoule@sympatico.ca</i>		E-mail <i>dianehoule@sympatico.ca</i>	
Role and responsibilities in emergency <i>ASSIST EVACUATE DIRECT FIRST RESPONDANT</i>		Role and responsibilities in emergency <i>ASSIST EVACUATE DIRECT FIRST RESPONDANT</i>	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Manager	
Name <i>DIANE HOULE</i>	For Office Use - Party No.	Name <i>DIANE HOULE</i>	For Office Use - Party No.
Official Title <i>MGR.</i>		Official Title <i>MGR.</i>	
Telephone No. <i>705-649-5631</i>	Fax No. <i>705-649-4100</i>	Telephone No. <i>705-649-4819</i>	Fax No. <i>705-649-4100</i>
E-mail <i>dianehoule@sympatico.ca</i>		E-mail <i>dianehoule@sympatico.ca</i>	
Role and responsibilities in emergency <i>ASSIST EVACUATE DIRECT FIRST RESPONDANT</i>		Role and responsibilities in emergency <i>ASSIST EVACUATE DIRECT FIRST RESPONDANT</i>	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name <i>JEFF BOWEN</i>	For Office Use - Party No.	Name <i>STEVE HILDERLEY</i>	For Office Use - Party No.
Official Title <i>FIRE CHIEF Goulais River Fire Hall</i>		Official Title	
Telephone No. <i>911-705-649-3039</i>	Fax No. <i>705-649-1943</i>	Telephone No. <i>705-949-6202</i>	Fax No. <i>705-949-2539</i>
E-mail <i>goulaisfire@xplornet.com</i>		E-mail <i>steve.hilderley@mcDougallcorp.com</i>	
Role and responsibilities in emergency <i>LOCAL FIRE HALL FIRE CHIEF FIRE OPERATIONS</i>		Role and responsibilities in emergency	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name <i>DAVID RYAN</i>	For Office Use - Party No.	Name <i>N/A</i>	For Office Use - Party No.
Official Title <i>DEPUTY CHIEF</i>		Official Title	
Telephone No. <i>705 649 3039</i>	Fax No. <i>705 649 1943</i>	Telephone No.	Fax No.
E-mail		E-mail	
Role and responsibilities in emergency <i>FIRE OPERATIONS</i>		Municipality <i>BLUEBERRY HILL MOTEL & CAMPGROUND LTD. 2550 R.R. #1 HWY 12N Goulais River ON P0S 1E0</i>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest J. Murdock</i>	Official Title <i>OWNER</i>
Signature <i>[Signature]</i>	Telephone No. <i>705-649-5631</i>
	Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

THE DISPENSER IS AWAY FROM HIGHWAY & FROM RESIDENCES OR LOCATION WHERE PEOPLES ARE PRESENT AT ALL TIMES

THERE IS THREE ALTERNATIVES ROAD TO EVACUATE PEOPLES IF NEEDED

IN CASE OF FIRE: 120,000 L. OF WATER FROM THE INDOOR POOL IS AVAILABLE FOR WHEN THE TANKER TRUCKS ARE EMPTY & NEED REFILLING AT THE POND.

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
2528 D.R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest by Murdoch</i>	Official Title <i>OWNER</i>
Signature <i>[Signature]</i>	Telephone No. <i>705-649-7631</i>
	Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy) 10/10/11	Print Name of Training Provider: OWNER / MANAGER
	Print Name of Instructor: D. Houle
Training Date (dd-mm-yyyy) 08/06/11	Print Name of Training Provider: OWNER / MANAGER
	Print Name of Instructor: D. Houle
Training Date (dd-mm-yyyy) 04/02/10	Print Name of Training Provider: OWNER / MANAGER
	Print Name of Instructor: D. Houle

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider: SAME
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider: SAME
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

NOTE: The OWNER the manager & the one staff all have been certified.

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
2528 D R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ernest L. Merdock	Official Title OWNER
Signature E. Merdock	Telephone No. 705-649-5631
	Date (dd-mm-yyyy) 10-10-11



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy) 01-03-12	Print Name of Training Provider: OWNER/MANAGER
	Print Name of Instructor: D. Houle
Target Date (dd-mm-yyyy) 01-05-12	Print Name of Training Provider: OWNER/MANAGER
	Print Name of Instructor: D. Houle
Target Date (dd-mm-yyyy) 01-09-12	Print Name of Training Provider: OWNER/MANAGER
	Print Name of Instructor: D. Houle

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider: SAME
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider: SAME
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

NOTE: the OWNER, MANAGER & 1 staff have all been certified.

BLUESBERRY HILL MOTEL & CAMPGROUND LTD
5828 D.P.R. HWY 17N
Gondare River, ON P0S 1E0

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Ernest L. Merdack	Official Title OWNER
Signature <i>E. Merdack</i>	Telephone No. 705-649-7631
	Date (dd-mm-yyyy) 10-10-11



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).

As soon as problem is detected staff will advise Mgr. & owner. & will block roads access to guests call 911, & direct guests to safe evacuation route. Mgr will advise McDougalls of problem.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

STAFF will cordon off dispenser area & ADVISE GUESTS OF EVACUATION ROUTE. Provide ANSWERS TO FIRST RESPONDANT & HELP AS INSTRUCTED BY PROFESSIONAL.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

OWNER OR MANAGER IS ON SITE AT ALL TIME. AS SOON AS PROBLEM IS DETECTED 911 will be CONTACTED.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

SITE IS NOT IN LOCKED DOWN LOCATION - THERE IS NO GATE

Describe how the licence holder will ensure continual flow of updated information to authorities.

LAND LINE ARE IN ANOTHER LOCATION & cell coverage is available
license holder will physically be present & is known to the local fire crew.

How long will it take the facility liaison person to respond to the site.

OWNER OR MANAGER ARE ON SITE AT ALL TIMES.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest L. Murdock</i>		Official Title <i>OWNER</i>	
Signature <i>E.L. Murdock</i>		Telephone No. <i>705-647-5631</i>	Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
2. Is there adequate night lighting at the site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input checked="" type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	<input checked="" type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input checked="" type="checkbox"/>	<input type="checkbox"/>

NIA

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input type="checkbox"/>	<input checked="" type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)		<u>50 m. POOL.</u>
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)		<u>1000 m.</u>

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
2528 D.R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0

I declare that I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest L. Murdoch</i>	Official Title <i>OWNER</i>	
Signature <i>E. Murdoch</i>	Telephone No. <i>705-649-1631</i>	Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

SITE HAS EASY ACCESS AND IS WELL MARKED. NO ACTION REQUIRED

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

N/A.

The Licence holder will respond to the Local Fire Services comments by: _____
(dd-mm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name <i>JEFF BOWEN</i>	Signature <i>Jeff Bowen</i>	Date (dd-mm-yyyy) <i>07-10-2011</i>
Local Fire Services Name <i>GOULAIS FIRE & RESCUE</i>		

*BLUESBERRY HILL MOTEL & CAMPGROUND LTD
258 D R R #2 Hwy 11N
London ON N6G 1P6*

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest L. Merdeck</i>	Official Title <i>OWNER</i>
Signature <i>E. Merdeck</i>	Telephone No. <i>705-649-7631</i> Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below.

Required Mapping Information from Updated Site Plan

Date Map Prepared (dd-mm-yyyy) <i>19-09-2011</i>	Capacity of single largest propane storage vessel (USWG) <i>1000</i>
Tank setback coordinates. Indicate placement on the map.	
Front: <i>265 m.</i>	Right side property line: <i>70 m.</i>
Rear: <i>266.5 m</i>	Left side property line: <i>269 m.</i>
GPS coordinates of single largest vessel: <i>N 46° 42' 42.3" W 84° 20' 27.4"</i>	

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
2528 D R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest J. MacIsaac</i>	Official Title <i>OWNER</i>
Signature <i>[Signature]</i>	Telephone No. <i>705-649-8032</i>
	Date (dd-mm-yyyy) <i>19-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Table 1: Distance Table


Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
 D = Distance to overpressure of 1 psi (meters)
 C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
 Assume all vessels are 80% full
 1 gallon [US, liquid] = 0.003785411784 cubic meter
 1 cubic metre = 264.17 USWG

BLUEBERRY HILL MOTEL & CAMPGROUND LTD.
 2528 D.R.R.#2 Hwy 17N
 Goulais River, ON P0S 1E0

Hazard Distance Chart (EPA-TNT model)



Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest L. Murdoch</i>		Official Title <i>OWNER</i>	
Signature <i>E.L. Murdoch</i>		Telephone No. <i>705 649-1631</i>	Date (dd-mm-yyyy) <i>10-10-11</i>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: <u>Iqloo (SEASONAL USE)</u> Address: <u>2528 D HWY 17N</u> City: <u>Goulais River</u> Province <u>ON</u> Postal Code <u>R0S1E0</u>		X			<u>11</u> m
Residential building units specifically permanent single family dwellings, condominiums, and apartments [REDACTED]		X			<u>46</u> m
Commercial building units, specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>031 20 N/A</u> Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Commercial building units - continuous occupancy specifically hotels, campgrounds, and resorts. <u>CABIN</u> Name: <u>OFFICE - MOTEL - POOL - LAUNDRY MAT</u> Address: <u>2528 D HWY 17N</u> City: <u>Goulais River</u> Province <u>ON</u> Postal Code <u>R0S1E0</u>		X			<u>43</u> m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: <u>N/A</u> Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: <u>N/A</u> Address: _____ City: _____ Province _____ Postal Code _____					_____ m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Ernest L. Merdiah</u>	Official Title <u>OWNER</u>	
Signature <u>E. Merdiah</u>	Telephone No. <u>705-649-5631</u>	Date (dd-mm-yyyy) <u>10-10-11</u>



Technical Standards and Safety Authority
www.tssa.org

14th Floor - Centre Tower
3300 Bloor Street West
Toronto Ontario M8X 2X4
Fax: 416.231.4903
Customer Service: 1.877.682.8772

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Portable Storage Additional Information Sheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG	
# 420	123.9			
# 100	29.5			
# 40	11.75	N/A		
# 33.3	9.62			
# 30	8.8			
# 20	5.8			
# 10	2.9			
# 5	1.5			
Total Cylinder Capacity				

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
Total Tank Capacity		

Total Cylinder Capacity	
Total Tank Capacity	
Total Portable Capacity	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <i>Ernest J. Merdiah</i>		Official Title <i>OWNER</i>	
Signature <i>EJ Merdiah</i>		Telephone No. <i>705-649-5631</i>	Date (dd-mm-yyyy) <i>10-10-11</i>

- 1- ONE FIRE EXTINGUISHERS (DISPENSER) NO STORAGE
- 2- 1000 USGAL
- 3- COTTAGE, IGLOO, MAIN BLDG.
- 4- CEMENT PILONS AROUND DISPENSER NO GATES
- 5- FIRE EXTINGUISHERS AT DISPENSER IN IGLOO & MAIN BUILDING
- 6- OUTSIDE WALL OF IGLOO
- 7- DISPENSER ONLY
- 8- 20' R/W

C-1	5 27.0 W	130.0
C-2	N 43.0 W	218.0
C-3	N 25.0 W	350.0
C-4	N 7.0 W	500.0



Part 1	Pl. NW 1/4 - Sec. 42	Pl. NW 1/4 - 45336
Part 2	"	"
Part 3	"	"
Part 4	"	"
Part 5	Pl. NW 1/4 - Sec. 42	Pl. NW 1/4 - 45336

DEPOSITED UNDER ACT
 No. 29 1979
 DATE July 21 1979
 FOR F. C. WILSON

9- Circle 195 m
 10- No municipality
 11- BLUE LINE
 12- Hwy 17 D only

13- 2x38 D HWY
 14- unorganized Township

HIGHWAY 17
 INST. N° 7. 45335




339.4 m
 1021.5 m

DEPOSITED UNDER ACT
 No. 29 1979
 DATE July 21 1979
 FOR F. C. WILSON

DEPOTES BRASS CAP
 DENOTES PLANTED
 DENOTES WITNESS
 DENOTES FOUND

SW CORNER OF SEC. 42 OF 1874 F.D.



**BLUEBERRY HILL MOTEL &
CAMPGROUND LTD.
2528 D R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0**

BLUEBERRY HILL MOTEL &
CAMPGROUND LTD.
2528 D.R.R.#2 Hwy 17N
Goulais River, ON P0S 1E0

