



Fuels Safety Program	Ref. No.: FS – 119-08	Rev. No.:
ADVISORY	Date: May 12, 2008	Date:

Subject: Sizing Oil Vents (Flues) – Burner Input (Table 1 & 2)
Sent to: Posted on Web-Site

When sizing vents/flues for oil burning appliances using Table 1 or 2 included in the Ontario Installation Code for Oil Burning Equipment, the actual burners' firing rates shall be used to determine the total input rating of all connected appliances (do not use maximum firing rates).

If the oil burner technician wants to change the burner(s) firing rate(s) within the burner(s) specifications, he or she shall ensure the vent/flue size will comply with Table 1 or 2; or the vent/flue shall be replaced accordingly.