



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

**New Propane Refill or Propane Refilling Plant -
Level 1 Risk and Safety Management (RSMP) Form**
Technical Standards and Safety Act
Propane Storage and Handling Regulation

This Level 1 RSMP applies to: • a facility with a total propane storage capacity of 5,000 USWG or less; or
• a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

**Failure to fully complete this form may result in rejection.
Making a false statement may result in a fine or prosecution
under the *Technical Standards and Safety Act***

Licence Number _____

Check applicable type of propane operations.

Cylinder Motor Fill Filling Plant Card/Keylock

Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.

For Office Use Only

SECTION A: GENERAL INFORMATION

**The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*,
Propane Storage and Handling Regulation.**

Company Name

Corporation No.

A

Operator Name (if different from above)

Telephone No. Fax No. E-mail

B

Street No. Street Name / 911 Number / Address, if applicable

Town / City or Township / County

Province

Postal Code

Mailing address if different from above.

C

Street No. Street Name / 911 Number / Address, if applicable

Town / City or Township / County

Province

Postal Code

Information on Container Refill Centre or Filling Plant

Location of facility.

D

Street No. Street Name / 911 Number / Address, if applicable

Nearest Major Intersection

Town / City or Township / County

Province

Postal Code

Name of Licence Holder

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT).

□□□□□□□□□

Municipality (or municipalities if the facility or its hazard distance touches multiple borders)

Hours of operation.

Monday: _____ am _____ pm

Friday: _____ am _____ pm

Tuesday: _____ am _____ pm

Saturday: _____ am _____ pm

Wednesday: _____ am _____ pm

Sunday: _____ am _____ pm

Thursday: _____ am _____ pm

Holiday: _____ am _____ pm

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Print name

Signature

Date (dd-mmm-yyyy)

Name of Licence Holder _____

Name of Senior Management person as defined in the

Regulation holding the Record of Training _____



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established. Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment.

Identify the psig rating and serial number for each fixed propane storage tank on site.

PSIG

Serial Number

Tank1: _____

Tank2: _____

Tank3: _____

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: _____ Portable: _____ Mobile: _____

Activity Information

To protect the confidentiality of this information, it will be protected by the Technical Standards and Safety Authority (TSSA) and fire services as sensitive, competitive information under provincial and municipal privacy legislation.

Note: Newly built facilities are to complete this section with best available estimates.

Provide the following information for the most recent 12-month period.

Description	Months											
	Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
Throughput (litres)												
Maximum No. of transfers (if applicable)												
Number of Deliveries received.....												
Number of Cylinder-fills.....												
Number of Motor-fills												

Provide the daily throughput on the ten highest throughput days of the past year and dates of occurrences.

Date of Occurrence (dd-mm-yyyy)	Throughput(litres)	Date of Occurrence (dd-mm-yyyy)	Throughput(litres)
1. _____	_____	6. _____	_____
2. _____	_____	7. _____	_____
3. _____	_____	8. _____	_____
4. _____	_____	9. _____	_____
5. _____	_____	10. _____	_____

If throughput exceeds the fixed storage capacity of the site, provide an explanatory note as to the cause.

Page 1

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title
Signature	Telephone No. Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s)		For Office Use - Party No.	
Street No.	Street Name Lot / Concession No.		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Name of Propane Transporter. If same as above, please check box. <input type="checkbox"/>		For Office Use - Party No.	
Street No.	S Street Name/ 911 Number/Address, if applicable		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	
E-mail			

Off-site Cylinder and/or Mobile Storage		Capacity stored off-site, in USWG	For Office Use - Party No.
Street No.	Street Name Lot / Concession No.		
Town / City or Township / Country		Province	Postal Code
Telephone No.	Fax No.	Contact Name	

Note: Customer storage is not considered off-site storage.

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)		Official Title	
Signature		Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

Description of fire and emergency equipment indicated on facility site map.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

Maintenance and testing schedule for fire protection controls and devices.

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact		5. Facility 24-Hour Contact Person	
Name	For Office Use - Party No.	Name	For Office Use - Party No.
Official Title		Official Title	
Telephone No.	Fax No.	Cell No.	Fax No.
E-mail		E-mail	
Role and responsibilities in emergency		Role and responsibilities in emergency	
2. Facility Contact Personnel - Alternate Contact		6. Name of Facility Manager	
Name	For Office Use - Party No.	Name	For Office Use - Party No.
Official Title		Official Title	
Telephone No.	Fax No.	Telephone No.	Fax No.
E-mail		E-mail	
Role and responsibilities in emergency		Role and responsibilities in emergency	
3. Local Fire Services - Key Contact		7. Propane Supplier Key Contact Person	
Name	For Office Use - Party No.	Name	For Office Use - Party No.
Official Title	E-mail	Official Title	E-mail
Telephone No.	Fax No.	Telephone No.	Fax No.
Role and responsibilities in emergency		Role and responsibilities in emergency	
Fire Services Address		Propane Supplier Address	
4. Local Fire Services - Alternate Contact		8. Municipal Contact	
Name	For Office Use - Party No.	Name	For Office Use - Party No.
Official Title	E-mail	Official Title	
Telephone No.	Fax No.	Telephone No.	Fax No.
Role and responsibilities in emergency		E-mail	
Fire Services Address		Municipality Name and Address	

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)		Official Title	
Signature		Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act

Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mm-yyyy)	Print Name of Training Provider:
	Print Name of Instructor:

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

Describe how the licence holder will ensure continual flow of updated information to authorities.

How long will it take the facility liaison person to respond to the site.

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures

	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is there adequate night lighting at the site?	<input type="checkbox"/>	<input type="checkbox"/>
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	<input type="checkbox"/>	<input type="checkbox"/>
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	<input type="checkbox"/>	<input type="checkbox"/>
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	<input type="checkbox"/>	<input type="checkbox"/>
6. Are weighing systems validated for accuracy?	<input type="checkbox"/>	<input type="checkbox"/>
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	<input type="checkbox"/>	<input type="checkbox"/>
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled? (e.g., QCC valves)	<input type="checkbox"/>	<input type="checkbox"/>
9. Is the schedule of maintenance and testing activities retained on site?	<input type="checkbox"/>	<input type="checkbox"/>

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	<input type="checkbox"/>	<input type="checkbox"/>
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	<input type="checkbox"/>	<input type="checkbox"/>
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)	<hr/>	
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	<hr/>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes No

If not, please explain (e.g., no fire services).

Fire services comments, if any:

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

The licence holder will respond to the Local Fire Services comments by: _____

(dd-mmm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name

Signature

Date (dd-mmm-yyyy)

Local Fire Services Name

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.

The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below .

Required Mapping Information from Updated Site Plan

Date map prepared (dd-mmm-yyyy)	Capacity of single largest propane storage vessel (USWG)
Tank setback coordinates. Indicate placement on the map.	
Front: _____	Right side property line: _____
Rear: _____	Left side property line: _____
GPS coordinates of single largest vessel: _____	

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$

D = Distance to overpressure of 1 psi (meters)

C = Tank Total Capacity in USWG


Parameters: Density of Propane is 0.5033 kg per litre @ 15 C

Assume all vessels are 80% full

1 gallon [US, liquid] = 0.003785411784 cubic meter

1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)





Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: _____ Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____					_____ m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: _____ Address: _____ City: _____ Province _____ Postal Code _____					_____ m

* For multi-unit buildings, count each unit as "1".

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)	Official Title	
Signature	Telephone No.	Date (dd-mmm-yyyy)



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
customerservices@tssa.org
www.tssa.org

New Propane Refill or Propane Refilling Plant - Level 1 Risk and Safety Management (RSMP) Form

Technical Standards and Safety Act
Propane Storage and Handling Regulation

WORKSHEET

Portable Storage Additional Information Worksheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8		
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
Total Tank Capacity		

Total Cylinder Capacity	
Total Tank Capacity	
Total Portable Capacity (Total Cylinder Capacity + Total Tank Capacity)	

*Information provided in this application is releasable under the Freedom of Information and Privacy Protection Act and may be disclosed upon request.