



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP) Technical Standards and Safety Act Propane Storage and Handling Regulation

This Level 1 RSMP applies to:

- a facility with a total propane storage capacity of 5,000 USWG or less; or
- a facility with a fixed propane storage capacity of exactly 5,000 USWG and no more than 500 USWG of portable propane storage capacity on site.

Failure to fully complete this form may result in rejection. Making a false statement may result in a fine or prosecution under the <i>Technical Standards and Safety Act</i> Licence Number <u>FS-LIC-56402</u> Check applicable type of propane operations. ☒ Cylinder ☐ Motor Fill ☐ Filling Plant ☐ Card/Keylock Submit along with this completed application a Facility Site Plan and a Map of the Surrounding Area.	For Office Use Only
--	---

SECTION A: GENERAL INFORMATION

The Undersigned applies to TSSA for a review for an RSMP under Ontario's *Technical Standards and Safety Act*, Propane Storage and Handling Regulation.

A Company Name The A&V Company Inc. Corporation No. 002713951

Operator Name (if different from above) _____

Telephone No. 647-949-1000 Fax No. n/a E-mail pioneerfraserville@theanvcompany.com

B Street No. 1315 Street Name / 911 Number / Address, if applicable County RD 28

Town / City or Township / County Fraserville Province ON Postal Code K0L 1V0

Mailing address if different from above.

C Street No. _____ Street Name / 911 Number / Address, if applicable Same As Above

Town / City or Township / County _____ Province _____ Postal Code _____

Information on Container Refill Centre or Filling Plant

D Location of facility.

Street No. 1315 Street Name / 911 Number / Address, if applicable County RD 28 Nearest Major Intersection Hwy 115/7 and County Rd 28

Town / City or Township / County Fraserville Province ON Postal Code K0L 1V0

Name of Licence Holder Anshul Yadav

Name of a Senior Management person as defined in the regulation holding the Record of Training (ROT). Kamal Kishor Yadav □□□□□□□□ PP0-3C

Municipality (or municipalities if the facility or its hazard distance touches multiple borders) Township of otonabee south monaghan

Hours of operation.

Monday:	<u>05</u> am <u>11</u> pm	Friday:	<u>05</u> am <u>11</u> pm
Tuesday:	<u>05</u> am <u>11</u> pm	Saturday:	<u>06</u> am <u>11</u> pm
Wednesday:	<u>05</u> am <u>11</u> pm	Sunday:	<u>06</u> am <u>10</u> pm
Thursday:	<u>05</u> am <u>11</u> pm	Holiday:	<u>06</u> am <u>10</u> pm

This document is valid until the next licence renewal date. You are required by law to notify TSSA of any change of information.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Print name	Signature	Date (dd-mm-yyyy)
Name of Licence Holder <u>Anshul Yadav</u>		<u>14-Jun-2026</u>
Name of Senior Management person as defined in the Regulation holding the Record of Training <u>Kamal Kishor Yadav</u>		<u>14-Jun-2026</u>



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Indicate the year the facility was established.

2000

Indicate the year of any significant modifications, as defined in s.1, O.Reg 211/01, since establishment.

N/A

Identify the psig rating and serial number for each fixed propane storage tank on site.

PSIG

Serial Number

Tank 1: 250 PSIG 1601-20
Tank 2: _____
Tank 3: _____

Enter capacity of propane in USWG, fixed, portable, and mobile, and provide detailed inventory that includes the number of tank/vessel for each type (fixed, portable, and mobile) and the capacity of each tank/vessel, on a separate document.

Fixed: 2000 USWG Portable: 139.2 USWG Mobile: 0 USWG

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title		
Anshul Yadav	Owner		
Signature		Telephone No.	Date (dd-mmm-yyyy)
		705-939-2929	14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION A: GENERAL INFORMATION (cont'd)

Activity Information

Name of Propane Supplier(s) Maple Leaf Propane			For Office Use - Party No.	
Street No. C2280		Street Name / 911 Number / Address Cameron Street East		
Town / City or Township / Country Cannington		Province ON	Postal Code L0E 1E0	
Telephone No. 416-200-6492	Fax No. N/A	Contact Name Rob McCullough		
E-mail mapleleafpropane@gmail.com				

Name of Propane Transporter. If same as above, please check box. ☐			For Office Use - Party No.	
Street No. 5		Street Name / 911 Number / Address Cuddy Boulevard		
Town / City or Township / Country London		Province ON	Postal Code N5V 3Y3	
Telephone No. 519-690-0000	Fax No. 1-519-690-1948	Contact Name Joe Erskine		
E-mail info@edproenergy.com				

Off-site Cylinder and/or Mobile Storage N/A		Capacity stored off-site, in USWG	For Office Use - Party No.	
Street No.		Street Name / 911 Number / Address		
Town / City or Township / Country		Province	Postal Code	
Telephone No.	Fax No.	Contact Name		

Note: Customer storage is not considered off-site storage.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Anshul Yadav		Official Title Owner	
Signature		Telephone No. 705-939-2929	Date (dd-mm-yyyy) 14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN

The licence holder will complete Section B in consultation with the local Fire Services.

Description of the maximum volume, types and storage location of other hazardous materials on site, if any.

The site has 1x2,000 USWG Vertical propane tank and 1 cylinder cage holding up to 24x20lb cylinders.

Facility also has underground gasoline and diesel tanks that contain gasoline, premium and diesel fuel (180,000 litres in total).

All underground tanks are fibreglass double walled. There are no hazardous materials on site.

The facility is an operating gas station with a convenience store/food service.

Description of fire and emergency equipment indicated on facility site map.

The facility is equipped with fire extinguishers. There is one located at the propane tank, four located at the gasoline islands and one located in the c-store.

There is a remote Emergency Shut Down (ESD) located on one of the posts at the propane tank.

The ESD kills power to the propane and stops the motor and closes the fuel supply solenoid valve to prevent product flow.

List of fire protection controls (e.g., fire detection systems, fire notification systems, alarm systems, automatic shut off devices, fusible links, etc.) and describe their function, use and operation.

The propane tank is equipped with a fusible link connected to a chain that will melt at 212 degrees F which will break the chain and the spring loaded ISC valve will close automatically shutting off the propane suction to the pump. There is an Emergency Shut Down (ESD) located at the tank.

The ESD kills power to the propane and stops the motor and closes the fuel supply valve to prevent product flow.

The site has security cameras located at various locations that are monitored.

Maintenance and testing schedule for fire protection controls and devices.

The fire extinguishers are checked annually for proper operation.

The propane equipment and ESD is inspected annually by a TSSA registered contractor. Copies of Inspection reports are keep on site.

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print)

Anshul Yadav

Official Title

Owner

Signature

Telephone No.

705-939-2929

Date (dd-mmm-yyyy)

14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

1. Contacts for Emergency Response

1. Facility Contact Personnel - Key Contact

Name	For Office Use - Party No.
Anshul Yadav	
Official Title	
Owner	
Telephone No.	Fax No.
647-949-1000	N/A
E-mail	
cadetanshul@gmail.com	
Role and responsibilities in emergency	
Ensures that all employees are trained to work with propane and enforces the site safety plan in response to emergencies.	

5. Facility 24-Hour Contact Person

Name	For Office Use - Party No.
Kamal Kishor Yadav	
Official Title	
Owner	
Cell No.	Fax No.
416-970-6022	N/A
E-mail	
eokamalyadav@gmail.com	
Role and responsibilities in emergency	
Will assist the key contact in emergencies and will assume responsibility for site liaison if key contact is away from site. Will make 911 call.	

2. Facility Contact Personnel - Alternate Contact

Name	For Office Use - Party No.
Kamal Kishor Yadav	
Official Title	
Owner	
Telephone No.	Fax No.
416-970-6022	N/A
E-mail	
eokamalyadav@gmail.com	
Role and responsibilities in emergency	
Will assist the key contact in emergencies and will assume responsibility for site liaison if key contact is away from site. Will make 911 call.	

6. Name of Facility Manager

Name	For Office Use - Party No.
Kamal Kishor Yadav	
Official Title	
Owner	
Telephone No.	Fax No.
416-970-6022	N/A
E-mail	
eokamalyadav@gmail.com	
Role and responsibilities in emergency	
Will assist the key contact in emergencies and will assume responsibility for site liaison if key contact is away from site. Will make 911 call.	

3. Local Fire Services - Key Contact

Name	For Office Use - Party No.
Chuck Parsons	
Official Title	E-mail
Fire Chief	firechief@osmtownship.ca
Telephone No.	Fax No.
705-295-6880 Ext. 217	705-295-6786
Role and responsibilities in emergency	
Coordinates incident response activities and assigns the resources as required during emergencies.	
Fire Services Address	
21 Third Street, Keene, ON, K0L 2G0	

7. Propane Supplier Key Contact Person

Name	For Office Use - Party No.
Joe Erskine	
Official Title	E-mail
General Manager	info@edproenergy.com
Telephone No.	Fax No.
1-519-690-0000	1-519-690-1948
Role and responsibilities in emergency	
Coordinates truck deliveries and would initiate the CPA Emergency Response Plan as required.	
Propane Supplier Address	
5 Cuddy Boulevard, London, Ontario N5V 3Y3	

4. Local Fire Services - Alternate Contact

Name	For Office Use - Party No.
Mike De Grace	
Official Title	E-mail
Deputy Fire Chief	cwood@osmtownship.ca
Telephone No.	Fax No.
705-295-6880 ext 226	705-295-6786
Role and responsibilities in emergency	
Alternate contact will assist the Fire Chief in coordinating Fire Response and Resources in the event of an Emergency.	
Fire Services Address	
21 Third Street, Keene, ON, K0L 2G0	

8. Municipal Contact

Name	For Office Use - Party No.
Heather Scott	
Official Title	
Chief Administrative Officer/Clerk	
Telephone No.	Fax No.
705-295-6852 ext 223	705-295-6405
E-mail	
hscott@osmtownship.ca	
Municipality Name and Address	
Twp. of Otonabee-South Monaghan, 20 Third St., Box 70, Keene, ON, K0L 2G0	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print)	Official Title
Anshul Yadav	Owner
Signature	Telephone No.
	705-939-2929
	Date (dd-mm-yyyy)
	14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

2. Additional Safety Measures

Describe any other measures in place at the facility that exceed the minimum Code and Standards requirements.


Emergency Response Assistance Plan - available by contacting supplier.

The propane tank is protected with concrete filled posts on all sides and has emergency shutdown buttons that will kill power to the pump and close supply valve when pushed.

Fire Department Equipment access is easy off of County Rd 28 with adequate area to maneuver trucks around.

The site is monitored by security cameras.

**Declaration: I am aware that it is an offence to give false information in this document and
I hereby declare that the information I have given here is true and complete.**

Name of person completing this form (please print) Anshul Yadav	Official Title Owner
Signature 	Telephone No. 705-939-2929
	Date (dd-mm-yyyy) 14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

3. Record of Emergency Training Provided - For most recent 12-month period.

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Training Date(dd-mmm-y) 23-Jun-2026	Print Name of Training Provider:Fuels Training Centre
	Print Name of Instructor:Don Heyworth (1405)
Training Date(dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date(dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Training Date(dd-mmm-y) 23-Jun-2026	Print Name of Training Provider:Fuels Training Centre
	Print Name of Instructor:Don Heyworth (1405)
Training Date(dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date(dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Training Date(dd-mmm-y) 23-Jun-2026	Print Name of Training Provider:Fuels Training Centre
	Print Name of Instructor:Don Heyworth (1405)
Training Date(dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:
Training Date(dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Anshul Yadav	Official Title Owner	
Signature 	Telephone No. 705-939-2929	Date (dd-mmm-yyyy) 14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

4. Emergency Training Plan for Coming Year

Training on Emergency Response Plan and Procedures provided to facility key contacts.

Target Date (dd-mmm-y) TBD	Print Name of Training Provider: The A&V Company Inc.
	Print Name of Instructor: Kamal Kishor Yadav
Target Date (dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:

Training on the facility's Emergency Management Procedures provided to staff.

Target Date (dd-mmm-y) TBD	Print Name of Training Provider: The A&V Company Inc.
	Print Name of Instructor: Kamal Kishor Yadav
Target Date (dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:

On-site specific training provided to certificate holders / persons with Records of Training.

Target Date (dd-mmm-y) TBD	Print Name of Training Provider: Promar Petroleum Inc.
	Print Name of Instructor: Mike Martin
Target Date (dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:
Target Date (dd-mmm-y)	Print Name of Training Provider:
	Print Name of Instructor:

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Anshul Yadav	Official Title Owner
Signature 	Telephone No. 705-939-2929
	Date (dd-mmm-yyyy) 14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

5. Emergency Response Communications Plan

Warnings and Actions

Describe who gives warnings to whom, and how and when the warning will be given (including public notification as appropriate).

The attendant on site will notify the patrons at the propane facility that a problem has occurred after activating the ESD switch and closing the ISC valve.

The patrons will be asked to leave the site and the attendant will proceed to call 911 and ask for Fire Services and Police response.

After the call is made, the attendant will proceed to notify any staff and proceed to the "Muster Point" on site.

Describe what action is to be taken and by whom when a warning is issued (including details of a meeting place in a safe identified area and activating the evacuation plan, if necessary).

After a warning is issued the attendant will block off the entrance/exits to the site.

Once the area is free of customers, the staff will meet at the "Muster Point" and await the arrival of Emergency Responders.

Communication with Emergency Response Authorities

Describe when and how the licence holder will give early warning to emergency response authorities (including a process to ensure that a call is placed to 911).

Once an emergency situation is confirmed at the propane facility, the attendant will call 911 to ask for Fire and Police response.

The attendant always carries a cell phone and also has access to a phone inside the C-store.

A call will be made by any of the two means. After the call is made the attendant will await the arrival of the Emergency Responders.

The RSMP document is maintained on site in the office for presentation to the Emergency Responders.

Describe provisions for fire department entry when there are no operations or staffing at the propane site.

The site is not fenced so access to the site is always available to Emergency Responders from County Road 28. There are no barriers to the tank.

Describe how the licence holder will ensure continual flow of updated information to authorities.

The attendant will always be on site during normal business hours.

When Emergency Responders come to the site the attendant will identify themselves as the person who is responsible for the propane and will communicate directly with the Emergency Responders. The amount of product in the propane tank will be communicated to the Emergency Responders but daily records are not kept as it is not possible to determine the volume in a vertical propane tank as there are no gauges for quantity. Only records of sales are tabulated.

How long will it take the facility liaison person to respond to the site.

20 Minutes if not on site.

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Anshul Yadav	Official Title Owner
Signature [Redacted]	Telephone No. 705-939-2929
	Date (dd-mm-yyyy) 14-June-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

6. Building and Site Security and Procedures


	Yes	No
1. Does the propane location have controlled access to limit unnecessary risk and entry (lock out procedures)?	☒	☐
2. Is there adequate night lighting at the site?	☒	☐
3. Are procedures in place that ensure access routes, aisles, storage area, filling areas and the grounds are kept clear from unwanted materials?	☒	☐
4. Are there procedures that capture and record the daily inspection of hoses and inspection requirements for filling systems and mechanical devices used in the transfer of propane?	☒	☐
5. Does the facility have procedures that include a process to isolate and purge any overfilled propane cylinders?	☒	☐
6. Are weighing systems validated for accuracy?	☒	☐
7. Are storage areas clearly marked with the vessels' capacity status (i.e., filled, empty, purged and other hazardous materials)?	☐	☒
8. Are quality assurance procedures in place to ensure that all valves are closed after the propane cylinders are filled?(e.g., QCC valves)	☒	☐
9. Is the schedule of maintenance and testing activities retained on site?	☒	☐

7. Water Supply

The propane licence holder should work with the local fire department to determine water supply capabilities that are available based on the propane facility's location.

	Yes	No
1. Is a pressurized water system available at the propane facility site?	☐	☒
2. Can the municipal fire department pump 375 GPM (1420 LPM) of water at this location?	☒	☐
3. What is the unobstructed distance to the closest water supply that could be used for firefighting activities? (distance in metres only)		
4. What is the unobstructed distance to the closest approved water supply with year round access if there are no hydrants? (distance in metres only)	<u>within property - 60m</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Anshul Yadav	Official Title Owner	
Signature 	Telephone No. 705-939-2929	Date (dd-mm-yyyy) 14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION B: EMERGENCY AND PREPAREDNESS RESPONSE PLAN (cont'd)

The licence holder will complete Section B in consultation with the local Fire Services.

8. Licence holder and local Fire Services Review

To be completed by the Local Fire Services

Has the local fire service had an opportunity to review the Emergency Response and Preparedness Plan?

Yes



No



If not, please explain (e.g., no fire services).

Fire services comments, if any:

Empty grid for fire services comments.

To be completed by the Licence Holder

In response to the above comments, the following action(s) is required:

Empty lines for licence holder response.

The licence holder will respond to the Local Fire Services comments by: _____
(dd-mmm-yyyy)

LOCAL FIRE SERVICES

The undersigned has reviewed Section B of the Risk and Safety Management Plan Fire Services.

Print name	Signature	Date (dd-mmm-yyyy)
Local Fire Services Name Chuck Parsons - Fire Chief		14-Jun-2026

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) Anshul Yadav	Official Title Owner	
Signature 	Telephone No. 705-939-2929	Date (dd-mmm-yyyy) 14-Jun-2026



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS

Applicant must include a Facility Site Plan and Map of Surrounding Area

Facility Site Plan.

The licence holder will submit a copy of the original facility site plan updated with the following information:

1. The storage location of fixed, portable, and mobile vessels.
2. The maximum volume, types and storage location of hazardous materials.
3. Location of permanent structures on site.
4. Access and egress points and location of barriers.
5. Location of fire and emergency equipment (e.g., sprinkler systems, extinguishers, suppression systems) on site and location of fire hydrant or water supply where available.
6. Location of emergency shut off/shut down switches/valves.

Map of Surrounding Area.


The licence holder will submit a scaled aerial map of the surrounding area showing the following information:

7. The capacity and placement of the single largest propane storage vessel, including its setback from the front, rear and side property lines.
8. GPS co-ordinates of the single largest vessel.
9. Visual indication of the single largest fixed vessel and a circle made using the distance in Table 1 as the radius from the single largest fixed vessel.
10. Clear indication of the municipality or municipalities present within the circle.
11. Visual indication of property line information.
12. The location and name of roads within or abutting the site.
13. Key note to the drawing indicating the facility's municipal address, municipal lot number(s) and concession lines as applicable, and the date the map was prepared.
14. Address and contact information for each municipality (municipal clerk or secretary-treasurers of planning board). (Refer to page 5.)
15. Complete "Required Mapping Information from Updated Site Plan" in table below.

Required Mapping Information from Updated Site Plan

Date map prepared (dd-mmm-yyyy) <u>18 November 2021</u>	Capacity of single largest propane storage vessel (USWG) <u>2000 USWG</u>
Tank setback coordinates. Indicate placement on the map.	
Front: <u>23 feet (west)</u>	Right side property line: <u>184 feet (south)</u>
Rear: <u>129 feet (east)</u>	Left side property line: <u>11 feet (north)</u>
GPS coordinates of single largest vessel: <u>44°12'15.80"N, 78°23'12.24"W</u>	

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Anshul Yadav</u>	Official Title <u>Owner</u>	
Signature 	Telephone No. <u>705-939-2929</u>	Date (dd-mmm-yyyy) <u>14-Jun-2026</u>



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act

Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area


Table 1: Distance Table

Water Capacity (litres)	Nominal Water Capacity (USWG)	Distance to 1 psi overpressure (m)
1,890	500	155
3,780	1,000	195
4,920	1,300	213
6,620	1,750	235
7,130	1,885	241
7,560	2,000	246
18,900	5,000	333

Formula: $D = 16.94 \times (1.524 \times C)^{1/3}$
D = Distance to overpressure of 1 psi (meters)
C = Tank Total Capacity in USWG

Parameters: Density of Propane is 0.5033 kg per litre @ 15 C
Assume all vessels are 80% full
1 gallon [US, liquid] = 0.003785411784 cubic meter
1 cubic metre = 264.17 USWG

Hazard Distance Chart (EPA-TNT model)





Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)
Technical Standards and Safety Act
Propane Storage and Handling Regulation

SECTION C: SUBMISSIONS (cont'd)

Applicant must include a Facility Site Plan and Map of Surrounding Area

As an accompaniment to the Map of Surrounding Area, provide the following information about buildings and features present within the circle in Table 2.

Table 2: Buildings and Features

Buildings and Features Present within the Circle on the Map of the Surrounding Area AND Name and Address of Closest Building or Feature	* Number of Buildings and Features (mark with an "X")				Distance from Tank to Closest Building or Feature
	0	1	2-10	11+	
Industrial buildings or parks or golf courses Name: <u>N/A</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>N/A</u> m
Residential building units specifically permanent single family dwellings, condominiums, and apartments. Name: _____ Address: _____ City: _____				X	<u>80</u> m
Commercial building units specifically retail, restaurants, entertainment, theatres, and sporting complexes. Name: <u>Loyal Orange Lodge #46</u> Address: <u>Whitfield Road</u> City: <u>Fraserville</u> Province <u>ON</u> Postal Code <u>K0L 1V0</u>			X		<u>50</u> m
Commercial building units – continuous occupancy specifically hotels, campgrounds, and resorts. Name: <u>N/A</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Sensitive institutions specifically hospitals, schools and day cares, nursing and retirement homes, mental health institutions, and prisons. Name: <u>N/A</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m
Emergency responders specifically fire stations, ambulance stations, and police stations. Name: <u>N/A</u> Address: _____ City: _____ Province _____ Postal Code _____	X				<u>0</u> m

* For multi-unit buildings, count each unit as "1".

Declaration: I am aware that it is an offence to give false information in this document and I hereby declare that the information I have given here is true and complete.

Name of person completing this form (please print) <u>Anshul Yadav</u>	Official Title <u>Owner</u>
Signature _____	Telephone No. <u>705-939-2929</u>
	Date (dd-mm-yyyy) <u>14-Jun-2026</u>



Technical Standards and Safety Authority
345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel: 416.734.3300
Fax: 416.231.4078
Customer Service: 1.877.682.8772
propanelicensing@tssa.org
www.tssa.org

Level 1 Risk and Safety Management Plan (RSMP)

Technical Standards and Safety Act
Propane Storage and Handling Regulation

WORKSHEET

Portable Storage Additional Information Worksheet

Cylinder Size	Capacity in USWG	Quantity	Total Volume in USWG
# 420	123.9		
# 100	29.5		
# 40	11.75		
# 33.3	9.62		
# 30	8.8		
# 20	5.8	24	139.2 USWG
# 10	2.9		
# 5	1.5		
Total Cylinder Capacity			

Tanks Stored On-site Not Connected for Use

Tank Size In USWG	Quantity	Total Volume in USWG
Total Tank Capacity		

Total Cylinder Capacity	139.2 USWG
Total Tank Capacity	0.0 USWG
Total Portable Capacity (Total Cylinder Capacity + Total Tank Capacity)	139.2 USWG

*Information provided in this application is releasable under the Freedom of Information and Privacy Protection Act and may be disclosed upon request.